



NOTES:

1. CROSS SLOPE OF SIDEWALK SHALL BE TWO PERCENT (2%) MAX INCLUDING OVER DRIVEWAY APPROACH.
2. SIDEWALK SHALL BE 4" THICKNESS, CLASS "A" CONCRETE WITH #3 REBAR AT 18" CENTERS UNLESS OTHERWISE SPECIFIED BY OWNER.
3. 1/2" EXPANSION JOINTS SHALL BE SPACED AT 40' MAXIMUM INTERVALS OR AS OTHERWISE SPECIFIED. JOINTS SHALL BE RED WOOD WITH MINIMUM THREE (3) #4 SMOOTH DOWELS AT 12" SPACING.
4. ALL SIDEWALKS CROSSING DRIVEWAYS SHALL BE SAME THICKNESS OF DRIVEWAY APPROACH.
5. ALL SIDEWALK CONSTRUCTION SHALL CONFORM TO THE LATEST A.D.A. RULES AND GUIDELINES AND TEXAS ACCESSIBILITY STANDARDS.
6. FOR ITEMS NOT SPECIFIED IN THIS DETAIL PLEASE REFER TO N.C.T.C.O.G. PUBLIC WORKS CONSTRUCTION STANDARDS.
7. OWNER/CONTRACTOR SHALL OBTAIN A R.O.W. CONSTRUCTION PERMIT PRIOR TO ANY WORK OR CONSTRUCTION. CONTACT TPW AT 817-598-4254.



DATE	03/2016
DRAWN BY	TPW

TRANSPORTATION AND
PUBLIC WORKS DEPARTMENT

CONCRETE SIDEWALK
WITH PARKWAY

SHEET. #

C28A